

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/SZ/2021/ 307

Dated: 5/4/21

FIRE SAFETY CERTIFICATE

Certified that the Kerala Educational Society (Kerala School),M-Block, Vikas Puri, New Delhi-110018 Comprised of ground plus two upper floors owned/occupied by Kerala Educational Society was issued NOC vide letter no. F6/DFS/MS/2010/2777 dated 23/09/2010.The school building was re- inspected by the officer concerned of this department on dated 01/04/2021 in the presence of Smt. Jayanth (Principal) of the school. The school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building (except multipurpose hall) is fit for occupancy Group B 'Educational Building' with effect from 5.4.21..... for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below..

Issued on.....5/4/21.....at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to:-

1. The Secretary,
Kerala Educational Society (Kerala School)
M-Block, Vikas Puri, New Delhi-110018.
2. Director of Education
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Multipurpose hall not in use for school activity
8. Basement shall be used as per the building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.